

Emerging Needs for a Generic IBR Model in EMT Domain

Jens Boemer, Technical Executive (<u>boemer@epri.com</u>) Contributors: EPRI, NREL, Southern Company

Electromagnetic Transient Simulation Workshop Oak Ridge National Lab Oak Ridge, August 24, 2023 Classif

Classification: public

ORNL is managed by UT-Battelle, LLC for the US Department of Energy



Acknowledgement

• This presentation is, in part, based upon work supported by the U.S. Department of Energy's Office of Energy Efficiency and Renewable Energy (EERE) under the Solar Energy Technologies Office Award Number DE-EE0009019.






Content

- Background & Motivation
- Proposed Generic EMT Model for PV and Storage— Specification & Validation Example
- Example Use Case related to FERC Order 2023— Improvements to Generator Interconnection Procedures and Agreements
- Remaining Gaps & Challenges



PV-MOD Project Overview https://www.epri.com/pvmod

Validated; publicly available models for various types of studies, reports detailing the research, close collaboration with industry stakeholders (NERC, WECC, IEEE, etc.)





CAK RIDGE National Laboratory This deliverable is, in part, supported by the U.S. Department of Energy, Solar Energy Technologies Office under Award Number DE-EE0009019 Adaptive <u>Protection and Validated MOD</u>els to Enable Deployment of High Penetrations of Solar PV (PV-MOD).




This deliverable is, in part, supported by the North American Electric Reliability Corporation (NERC) under EPRI contract 20011165 *Inverter-Based Resources Dynamic Response Characterization for Bulk Power System Protection, Planning, and Power Quality.*

Need for EMT models of IBRs

IEEE Power & Energy Society April 2020 TECHNICAL REPORT



Stability definitions and characterization of dynamic behavior in systems with high penetration of power electronic interfaced technologies



"Stability definitions and characterization of dynamic behavior in systems with high penetration of power electronic interfaced technologies," Technical Report April, 2020. [Online]. Available: <u>https://resourcecenter.ieee-</u>

pes.org/publications/technicalreports/PES_TP_TR77_PSDP_stability_051320.html



IEEE Standard for Interconnection and Interoperability of Inverter-Based Resources (IBRs) Interconnecting with Associated Transmission Electric Power Systems

S

D

4

TAND

N

IEEE Power and Energy Society

Developed by the Energy Development & Power Generation Committee, Electric Machinery Committee, and Power System Relaying & Control Committee

IEEE Std 2800™-2022

∲IEEE

"IEEE Standard for Interconnection and Interoperability of Inverter-Based Resources (IBRs) Interconnecting with Associated Transmission Electric Power Systems," in *IEEE Std 2800-2022*, vol., no., pp.1-180, 22 April 2022, doi: 10.1109/IEEESTD.2022.9762253.



https://www.nerc.com/pa/rrm/ea/Pages/Major-Event-Reports.aspx

MOD-026-2 – Verification of Dynamic Models and Data for BES Connected Facilities

A. Introduction

1. Title: Verification of Dynamic Models and Data for BES Connected Facilities

- 2. Number: MOD-026-2
- Purpose: To verify that the dynamic models and associated parameters used to assess Bulk Electric System (BES) reliability represent the in-service equipment of BES Facilities including generating Facilities, transmission connected dynamic reactive resources, and high-voltage direct current (HVDC) systems.

https://www.nerc.com/pa/Stand/Pages/Project-2020_06-Verifications-of-Modelsand-Data-for-Generators.aspx

Project 2022-04 EMT Modeling

Related Files

Status
The comment and nomination period for the Project 2022-04 EMT Modeling Standard Authorization Request (SAR) concluded at 8 p.m. Eastern, Tuesday, September 13, 2022.

Background

The bulk power system (BPS) in North America is undergoing a rapid transformation towards high penetrations of liveretra-based resources. Transmission Planners (TP) and Planning Coordinators (PC) are concerned about the lack of accurate modeling data and the need to perform electromagnet transmit (EMT) studies during the interconnection process and long-term planning horizon. The growth of inverter technology has pushed conventional planning tools to their limits in many ways, and TPs and PCs are now faced with the need to conduct more detailed studies using EMT models for issues related to inverter-based resource integration issue.

This SAR proposes including EMT models and studies in planning-related NERC Standards to ensure reliable operation of the BPS moving forward

Standard(s) Affected: FAC-002, MOD-032, and TPL-001

Purpose/Industry Need

This project addresses the reliability-related need and benefit by ensuring TPs and PCs have the models and tools necessary to adequately conduct reliability assessments under increasing levels of inverter-based resources. This requires the collection of EMT models by applicable entities and TPs and PCs to conduct EMT studies where needed.

https://www.nerc.com/pa/Stand/Pages/Project2022-04EMTModeling.aspx



Need for Generic Models

Transmission planning perspective

- Futuristic studies
- Development and communication of grid-specific performance requirements
- Investigation of site-specific requirements
- Existing facilities where EMT models are not available
- Education

But ... the model should be reasonable




Generic EMT Model for PV and Storage Based on IEEE Std 2800-2022 performance requirements

- Include control that allows the IBR to meet the IEEE Std 2800-2022 performance requirements
- Include varying levels of modeling simplifications
 - DC dynamics
 - Converter model
- Ensure the model is reasonable
 - Comparisons to commercial inverter responses

Ref: Generic Photovoltaic Inverter Model in an Electromagnetic Transients Simulator for Transmission Connected Plants: PV-MOD Milestone 2.7.3. EPRI, Palo Alto, CA: 2022 https://publicdownload.epri.com/PublicAttachmentDownload.svc/AttachmentId=82135



Generic EMT model PV or storage inverter model




Generic inverter model

- → Current-controlled, PWM VSC
- → Control implemented in dual dq frames: positive and negative sequences
- → Controllers developed based on IEEE 2800-2022 FRT response requirements
- → Setpoint controllers: Vdc, P, Vac, and Q

Ref: Generic Photovoltaic Inverter Model in an Electromagnetic Transients Simulator for Transmission Connected Plants: PV-MOD Milestone 2.7.3. EPRI, Palo Alto, CA: 2022 https://publicdownload.epri.com/PublicAttachmentDownload.svc/AttachmentId=82135



Generic EMT model Implemented in PSCAD™




0. inverter data	
Sinv: Inverter rated aparant power (VA)	1e6
VLL_base: inverter rated RMS voltage line-line (V)	600
fnom: nominal frequency	60.0
Lf: LC filter inductance	0.0001
Rf: LC filter resistance	0.00075
Cf: LC filter capacitance (uF)	147
Rd: LC filter damping resistance	0.05 [ohms]
Cdc: DC link capacitor capacitance (uF)	0.1e6
Vdc_nom: DC link voltage nominal	1200
fs: PWM switching frequency (switching model)	3060.0
tstart_up: Start-up time	2.0
1. control configuration	
Vsp_flg (1: enable inverter term. voltage control, (0
Qsp_CL_flg (1: closed loop Q control, 0: open loop	0
qt_flg (1: Q control at terminal after LC filter, 0: Q	1
Vdc_flg (1: enable Vdc control, 0: voltage source (0
PV_flg (1: enable PV array I-V characteristic, 0: co	0
MPPT_flg (1: enable MPPT for Vdc*, requires VI-fle	
f_flg (1: to enable frequency-droop control, 0: dis	0
2. reactive power - voltage control	
Qmax: reactive power maximum limit	0.4
Qmin: reactive power minimum limit	-0.4
iq1_max: reactive current maximum limit	99
iq1_min: reactive current minimum limit	-99
Kqp: Q closed-loop propotional gain	0
Kqi: Q closed-loop integral gain	40
Kvp: terminal voltage control proportional gain	0
Kvi: terminal voltage control integral gain	100
vt_ref: terminal voltage control reference setpoint	1.0
Tv: Voltage LPF time constant	0.01
3. Vdc control	
kp_vdc:Vdc propotional gain	5.18
ki_vdc: Vdcintegral gain	52.91
4. frequency-droop	
fdbd1: deadband for frequency droop control (< (-0.0006
fdbd2: deadband for frequency droop control (>0	
Dup: 1/Droop for low frequency	20.0
Ddn: 1/Droop for high frequency	20.0
Tfrq: 1st order LPF time constant for PLL frequence	
ing, the order of a million constant for FEE frequence	~

FRT	
m_pu: current limit	1.0
ri_flg: current priority (1: iq, 0: ip)	1
vrt: threshold for LVRT	0.9
hvrt: threshold for HVRT	1.1
1_frt_dbstep_flg: set FRTV1 deadband as step	0
qv1_lvrt: LVRT V1 proportional gain	2
qv1_hvrt: HVRT V1 proportional gain	2
1i_flg	1
qv 2: FRT V2 proportional gain	2
2_db: V2 FRT dead band	0.1
2_frt_dbstep_flg: set FRTV1 deadband as step	1
elI_flg	1
PLL	
p_pll: Propotional gainfor PLL	40
_pll: Integral gain for PLL	4
npllmax: PLL integrator windup limit	70
signal processing	
t_flg: Current filter flag (1: enable)	1
'lt_i: Current LPF time constant	0.00001
flt_flg: Voltage filter flag (1: enable)	1
lt_v: Voltage LPF time constant	0.00001
current control	
_cur: Proportional gain current controller	0.9
_cur: Integral gain current controller	900.0
ncurmax: anti-windup upper limit	99999
ncurmin: anti-windup lower limit	-99999
_ramp_up: Ramp rate for increasing active curre	1.0
ff_flg: (1: enable voltage feedforward, 0: disable	0
rff: Vff LPF time constant	0.0001

Ref: PRE-SW: Generic Photovoltaic Inverter Model in an Electromagnetic Transients Simulator for Transmission Connected Plants (PVMOD-EMT-IBR) v1.0 Beta. EPRI, Palo Alto, CA: 2023. 3002025889 Online: https://www.epri.com/research/products/00000003002025889




Generic EMT model FRT response tests: B-C fault at POI example




Ref: W. Baker, M. Patel, A. Haddadi, E. Farantatos, J. Boemer, "Inverter Current Limit Logic based on the IEEE 2800-2022 Unbalanced Fault Response Requirements", 2023 IEEE Power Engineering Society General Meeting



Validation example Laboratory testing of a 2.2 MVA commercial battery inverter





Varying residual voltage in faulted phases at the 13.2 kV bus

Fault type	Faulted Phase(s) Residual 13.2 kV Voltage [pu]
LILG	0.0, 0.1, 0.2, 0.3, 0.4, 0.5, 0.6, 0.7, 0.8, 0.9
LL (B-C)	0.0, 0.1, 0.2, 0.3, 0.4, 0.5, 0.6, 0.7, 0.8, 0.9

1. NREL test facility: https://www.nrel.gov/docs/fy19osti/72886.pdf


2. Draft Test Plan and Candidate Inverter List: Adaptive Protection and Validated MODels to Enable Deployment of High Penetrations of Solar PV (PV-MOD). EPRI, Palo Alto, CA: 2023. Milestones 1.3.2 and 1.3.3 report for DOE. Online: https://publicdownload.epri.com/PublicAttachmentDownload.svc/AttachmentId=82091 and https://www.epri.com/pvmod

3. W. Baker, D. Ramasubramanian, A. Huque, J. Boemer, V. Gevorgian, P. Koralewicz, E. Mendiola, "Validation of the Fault Ride-Through Response of a Generic EMT Inverter Model by Laboratory Testing", 2023 IEEE Power Engineering Society General Meeting



Validation example

Comparison of the EMT model's response ('model') to the measured response of the IUT ('lab') to balanced and unbalanced faults




Ref: W. Baker, D. Ramasubramanian, A. Huque, J. Boemer, V. Gevorgian, P. Koralewicz, E. Mendiola, "Validation of the Fault Ride-Through Response of a Generic EMT Inverter Model by Laboratory Testing", 2023 IEEE Power Engineering Society General Meeting

National Laboratory

Validation example

Instantaneous line-line voltage and current at fault inception



Ref: W. Baker, D. Ramasubramanian, A. Huque, J. Boemer, V. Gevorgian, P. Koralewicz, E. Mendiola, "Validation of the Fault Ride-Through Response of a Generic EMT Inverter Model by Laboratory Testing", 2023 IEEE Power Engineering Society General Meeting

CAK RIDGE

Validation example Summary


- The generic EMT inverter model provides a reasonable prediction of the commercial inverter's FRT response for various fault types, fault severity, and initial operating conditions.
- Differences in the transient periods are observed as expected.
 - Details of the commercial inverter's design and control are unknown.
 - All details of the test circuit are not known.
- Expectation is that inverter models developed by the inverter OEMs should be much more accurate.



Example Use Case IBR Performance Requirements

• Example IBR response for a LL fault

• Helps the communication of performance requirements to the IBR developer



Ref: Southern Company Interconnection Requirements for Transmission Connected Inverter-Based Resources. Online: <u>http://www.oasis.oati.com/woa/docs/SOCO/SOCOdocs/SOCO</u> IBR Interconnection-Technical-Requirements Effective 08-06-2023.pdf



Example Use Case Existing Interconnection Procedure as shaped by the FERC Large Generator Interconnection Process




Further Reading:

J. Boemer, A. Shattuck, J. Matevosyan, "Need for North American Interconnection Process Review", ESIG Blog Article, December 13, 2022.



Example Use Case Recommended Improvements to the Interconnection Process



But:

FERC Ruled with <u>Order 2023</u> on July 28, 2023, and declined to incorporate IEEE 2800-2022 by reference (for now).



FERC Order 2023 on Improvements to Generator Interconnection Procedures and Agreements (RM22-14)

Document Accession #: 20230728-3060 Filed Date: 07/28/2023

184 FERC ¶ 61,054 UNITED STATES OF AMERICA FEDERAL ENERGY REGULATORY COMMISSION

18 CFR Part 35

[Docket No. RM22-14-000; Order No. 2023]

Improvements to Generator Interconnection Procedures and Agreements

(Issued July 28, 2023)

AGENCY: Federal Energy Regulatory Commission

ACTION: Final rule.

SUMMARY: The Federal Energy Regulatory Commission (Commission or FERC) is

adopting reforms to its pro forma Large Generator Interconnection Procedures, pro forma

Small Generator Interconnection Procedures, pro forma Large Generator Interconnection

Agreement, and pro forma Small Generator Interconnection Agreement to address

interconnection queue backlogs, improve certainty, and prevent undue discrimination for

new technologies. The reforms are intended to ensure that the generator interconnection

process is just, reasonable, and not unduly discriminatory or preferential.

EFFECTIVE DATE: This final rule will become effective [INSERT DATE 60 DAYS

AFTER DATE OF PUBLICATION IN THE FEDERAL REGISTER

FOR FURTHER INFORMATION CONTACT:

Tristan Kessler (Technical Information) Office of Energy Policy and Innovation 888 First Street, NE Washington, DC 20426 (202) 502-6608 tristan.kessler@ferc.gov

CAK RIDGE

National Laboratory

18

 Issued July 28, 2023 (<u>link</u>), EPRI is currently reviewing and plans to host a summary webinar soon

Scope per NOPR

- Implement a first-ready, first-served study process
 - Interconnection information access
 - Cluster Study
 - Allocation of Cluster Study Costs
 - Allocation of Cluster Network Upgrade Costs
 - Shared Network Upgrades
 - Increased Financial Commitments and Readiness Requirements
 - Transition Process
- Improve interconnection queue processing speed
 - Elimination of the reasonable effort standard
 - Affected Systems
 - Optional Resource Solicitation Study
- Incorporate technological advancements
 - Increasing Flexibility in the Generator Interconnection Process
 - Incorporating Alternative Transmission Technologies into the Generator Interconnection Process
- Update modeling and performance requirements for system reliability
 Modeling and Performance Requirements for Non-Synchronous Generating Facilities
- FERC declined to incorporate IEEE 2800-2022 by reference and to include plant conformity assessment into interconnection process.

CAK RIDGE National Laboratory **Remaining Gaps & Challenges**

Related to Generic EMT Model Development

- Comprehensive validation and testing of EPRI's proposed model against IEEE 2800-2022 performance requirements is ongoing.
- Implementation and benchmarking of EPRI's proposed model in other EMT modeling software like EMTP-RV, PowerFactory, OpenDSS, etc. is ongoing.
- Continuous improvement and alignment with IEEE 2800-2022 and future revisions of the standard is necessary.

Related to Generic EMT Model Application

- IEEE 2800-2022 not yet broadly adopted by many ISOs/RTOs.
- Potential value of IEEE 2800-2022 not fully recognized by FERC.
- Revision of NERC Reliability Standards may consider IEEE 2800-2022 but will likely take many years.
- Neither EPRI's nor any other entity's proposed generic, IEEE 2800 conforming EMT model is "officially recognized".

References

- Model Specification
 - Generic Photovoltaic Inverter Model in an Electromagnetic Transients Simulator for Transmission Connected Plants: PV-MOD Milestone 2.7.3. EPRI, Palo Alto, CA: 2022 Online: <u>https://publicdownload.epri.com/PublicAttachmentDownload.svc/AttachmentId=82135</u>
 - W. Baker, M. Patel, A. Haddadi, E. Farantatos, J. Boemer, "Inverter Current Limit Logic based on the IEEE 2800-2022 Unbalanced Fault Response Requirements", 2023 IEEE Power Engineering Society General Meeting
- Model prototype in PSCAD™
 - PRE-SW: Generic Photovoltaic Inverter Model in an Electromagnetic Transients Simulator for Transmission Connected Plants (PVMOD-EMT-IBR) v1.0 Beta. EPRI, Palo Alto, CA: 2023. 3002025889 Online: <u>https://www.epri.com/research/products/00000003002025889</u>
- Model Validation
 - Draft Test Plan and Candidate Inverter List: Adaptive Protection and Validated MODels to Enable Deployment of High Penetrations of Solar PV (PV-MOD). EPRI, Palo Alto, CA: 2023. Milestones 1.3.2 and 1.3.3 report for DOE. Online: <u>https://publicdownload.epri.com/PublicAttachmentDownload.svc/AttachmentId=82091</u>
 - W. Baker, D. Ramasubramanian, A. Huque, J. Boemer, V. Gevorgian, P. Koralewicz, E. Mendiola, "Validation of the Fault Ride-Through Response of a Generic EMT Inverter Model by Laboratory Testing", 2023 IEEE Power Engineering Society General Meeting
- FERC Order 2023: Improvements to Generator Interconnection Procedures and Agreements
 - FERC Transmission Reform Paves Way for Adding New Energy Resources to Grid. News Release. FERC. July 27, 2023. Online: https://www.ferc.gov/news-events/news/ferc-transmission-reform-paves-way-adding-new-energy-resources-grid



Thank You!

ın

Jens Boemer, Technical Executive 206.471.1180 jboemer@epri.com

